

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7165-0075:163 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: Lawrence T. Flood (203) 484-1200

DESIGN: Model MS-4412B fire alarm control unit. Suitable for non-coded; local, auxiliary and remote station (protected premises); proprietary (protected premises, central station (protected premises) when used with appropriate option modules and additional separate listed equipment; automatic manual, waterflow and sprinkler supervisory (local only).

OPTIONS:	4412TM	Transmitter Module
	4412ZM	Zone Relay Module
	4412LM	LED Interface Module
	DP-4X	Dress Panel

Refer to listee's data sheet for other required/optional accessories. When required, accessories shall be listed by CSFM.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

Proprietary protected premises unit: the system shall be interconnected with Potter Model EFT-C electrically actuated transmitter (CSFM Listing No. 7330-0328:104).

Central station protected premises unit: the system shall be connected to either of the following transmitters: Firelite Model NOTI-FIRE 911/911A series with ADEMCO Model 685 (CSFM Listing No. 7165-0078:133) or MS-5012 (CSFM Listing No. 7165-0075:154) control unit, or separately listed compatible control unit.

06-07-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**